

CERTIFICATE OF CONFORMITY



420-0004-546	ISSUE	1	5-17-111	5-24-17
	EDO NO.	5-17-111		
Sht. of		1 of 3	APPD BY SGA DATE	
APPD		SA		

- HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS
- Certificate No: **FM16CA0192X**
- Equipment: **TLS 4-20mA Tank Level System**
(Type Reference and Name)
- Name of Listing Company: **AMETEK Drexelbrook**
- Address of Listing Company: **205 Keith Valley Rd
Horsham, PA 19044
USA**
- The examination and test results are recorded in confidential report number:

3061460 dated 25th April 2017

- FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CSA-C22.2 No. 0.4 :R2013, CSA-C22.2 No. 0.5:R2012, CSA-C22.2 No. 25:R2014,
CSA-C22.2 No. 30:R2012, CSA-C22.2 No. 94:R2011, CSA-C22.2 No. 213:R2013,
CSA-C22.2 No. 1010-1:2004, CAN/CSA 60079-0:2015, CAN/CSA 60079-1:2016,
CAN/CSA 60079-11:2014, CAN/CSA 60079-26:2016, CSA C22.2 No. 60079-31:2015,
CAN/CSA C22.2 No. 60529:2010 , ANSI 12.27.01:2003

- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
- Equipment Ratings:

Intrinsically Safe and Explosionproof for Class I, Division 1, Groups C & D, hazardous (classified) locations; Intrinsically Safe for Class I, Zone 0 & 1, Group IIB hazardous (classified) locations; Nonincendive for use in Class I, Division 2, Groups A, B, C, & D hazardous locations; Dust-Ignitionproof for Class II, III, Division 1, Groups E, F, G hazardous locations with an indoor / outdoor Type 4, 4X and an Ingress protection of IP67.

Certificate issued by:

J.E. Marquedant

 J.E. Marquedant
 Manager, Electrical Systems

25 April 2017

 Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
 T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Member of the FM Global Group

Canadian Certificate Of Conformity No: FM16CA0192X

11. The marking of the equipment shall include:

Explosionproof Class I, Division 1, Groups C, D, T4
 Intrinsically Safe Class I, Division 1, Groups C, D, T4
 Nonincendive Class I, Division 2, Groups A, B, C, D, T4
 Dust-Ignitionproof Class II, III, Division 1, Groups E, F, G, T4
 Ex ia/db Group IIB, T4 Ga/Gb
 Ex ia Group IIB, T4 Ga
 -40°C < Ta < +70°C
 Type 4, 4X, IP67

12. **Description of Equipment:**

General - The TLS Dual 4-20mA Tank Level System (TLS) is a system with Dual 4-20mA Hart Digital outputs for measuring Total Liquid Level, Liquid Level Interfaces, Temperature and System Diagnostics for use with a magnetostrictive level sensor. The system is equipped with either stainless steel or flexible probes. The electronics consist of a power supply module and intrinsically safe probe interface barrier module, which provides intrinsically safe outputs to the probe. An optional 4-button display is available for users to access the menu, which is either installed in the TLS System or the Digital Stik probe. The electronics are housed in an explosion-proof / flameproof dual compartment enclosure. The dual compartment enclosure consists of a Viewport Cover for the optional display, or Base and Lid Covers with threads of a M105 X 2 6g/6H thread form. The dual enclosures are separated by an inter-compartment lead-seal that uses Stycast 2651-40 with Catalyst 9 from Emerson and Cumming with a minimum cemented joint length of 12.7 mm. The sensor connections are made through and the two the entries into the field wiring compartment are M20 X 1.5 6H or 3/4 -14 NPT. The probe assembly and dual enclosure is separated by The Coupling/Cylindrical Seal Assembly. The Coupling/Cylindrical Seal Assembly contains a Male 3/4 inch NPT connection and one female 3/4 inch connection. The probe assembly and dual enclosure is separated by a cylindrical seal. The Coupling/Cylindrical Seal Assembly contains a Male 3/4 inch NPT connection and one female 3/4 inch connection. The probe assembly and dual enclosure is separated by the Coupling/Cylindrical Seal Assembly and optional Dual Seal or Coupling/Cylindrical Seal Assembly.

Ratings - The TLS 4-20mA Tank Level System has the following Entity Parameters:
 Vmax = 30V; Imax = 140mA; Pi = 1W; Ci = 0; Li = 0

Operating Temperature Range - The TLS 4-20mA Tank Level System has an operating temperature range of -40°C to +70°C.

M a b c d e. 316SS Rigid TLS Dual 4-20mA Tank Level System

Entity Parameters:

Vmax = 30V; Imax = 140mA; Pi = 1W; Ci = 0; Li = 0

a = Output: 2, 3.

b = Housing: 3, 4, 5, or 6.

c = Dual Seal: X, 1.

d = Material: B, S, or F.

e = 17 characters not affecting safety.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM16CA0192X

M a b c V d. UltraFlex TLS Dual 4-20mA Tank Level System.

Entity Parameters:

Vmax = 30V; Imax = 140mA; Pi = 1W; Ci = 0; Li = 0

a = Output: 2, 3.

b = Housing: 3, 4, 5, or 6.

c = Dual Seal: X, 1.

d = 17 characters not affecting safety.

13. Specific Conditions of Use:

1. The enclosure contains aluminum and is considered a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact or friction.
2. Consult the manufacturer if dimensional information on the flameproof joints is necessary.
3. The enclosure contains non-metallic enclosure parts., To prevent the risk of electrostatic sparking, the non-metallic surface should be cleaned with a damp cloth.
4. The O-ring material should not be subjected to environmental conditions which may adversely affect the partition wall.
5. The User shall permanently mark the protection type chosen. Once the type of protection has been marked it shall not be changed.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
25 th April 2017	Original Issue.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com